



SPB Number: 2022.0301
EQUIPMENT-MILLWORK UPDATE

[X] All Travel Center Stores

THE CLIPS BELOW ARE TAKEN FROM THE LH PROTOTYPE

Issued: 10/20/2022

STANDARD PLAN BULLETIN NOTICE
RaceTrac Engineering and Construction Division

- PANEL C & C1 UPDATES:** Updated Panel C & C1 to be 30A Main and MCB ratings. Relocated security monitor #5041 (C-7) and BOH security monitor #5041 (C-14) to Panel E. Relocated Fax/printer from C-10 to C-16. Relocated Site camera fiber optics 2 from C-16 to C-14. Relocated coin safe #5001 from C-11 to C-17.

- Sheets: E110, E111, E430 & E431
- Attachments: E430

Branch Panel: C

Location: RECEIVING 106

Supply From: D

Mounting: PRE-FABRICATED

Enclosure: PRE-FABRICATED

Volts: 120/240 1PH

Phases: 1

Wires: 3

A.I.C. Rating: 65,000 SERIES RATED

Mains Type: MCB

Mains Rating: 30 A

MCB Rating: 30A


Notes:

Notes	CKT	Circuit Description	Trip	Poles	A		B		Poles	Trip	Circuit Description	CKT	Notes
EM	1	BILL SAFE #5007	20 A	1	360	360			1	20 A	LOTTO RECEPTACLE	2	
EM	3	RECEPTACLES/INTERCOM #5002	20 A	1			470	800	1	20 A	CAT SCALE FUEL DESK #5219	4	EM
EM	5	COMPUTER SYSTEM #5003	20 A	1	360	600			1	20 A	CASH WRAP RECEPTACLES	6	EM
	7	SPARE	20 A	1			0	200	1	20 A	DATA RACK	8	EM,IG
EM	9	MONEY ORDER MACHINE #5099	20 A	1	300	0			1	20 A	SPARE	10	
	11	SPARE	20 A	1			0	720	1	20 A	DATA CLOSET RECEPTACLE	12	EM
EM,IG	13	GILBARCO CONSOLE RECEPTACLE	20 A	1	360	360			1	20 A	SITE CAMERA FIBER OPTICS 2	14	EM
EM	15	SITE CAMERA FIBER OPTICS 1	20 A	1			720	100	1	20 A	FAX/PRINTER #5004	16	EM
EM	17	COIN SAFE #5001	20 A	1	360	0			1	20 A	SPARE	18	
--	19	SPACE	--	1			--	--	1	--	SPACE	20	--
--	21	SPACE	--	1	--	--	--	--	1	--	SPACE	22	--
--	23	SPACE	--	1			--	--	1	--	SPACE	24	--
--	25	SPACE	--	1	--	--	--	--	1	--	SPACE	26	--
--	27	SPACE	--	1			--	0				28	
--	29	SPACE	--	1	--	0			2	30 A	MAIN BREAKER	30	
Total Load:					3060 VA		3010 VA						

Branch Panel: C1												
Location: RECEIVING 106				Volts: 120/240 1PH				A.I.C. Rating: 65,000 SERIES RATED				
Supply From: D1				Phases: 1				Mains Type: MCB				
Mounting: PRE-FABRICATED				Wires: 3				Mains Rating: 30 A				
Enclosure: PRE-FABRICATED				MCB Rating: 30 A								
Notes:												


2. **CAT SCALE FUEL DESK UPDATE:** Updated Cat Scale Fuel Desk equipment number to be #5219.

- Sheets: A141, A160, E002, E111 & E430
- Attachments: E111




3. **PATIO TABLE SPACING:** Adjusted the spacing for the patio tables to be 6'-0" apart from each other.

- Sheet: A100
- Attachments: A100




4. **RAMP AT CASHWRAP:** Adjusted the width of ramp at Cashwrap to be 3'-0" .

- Sheet: A160
- Attachments: A160




5. **THREE-COMPARTMENT SINK:** Replaced 3-Compartment Sink EQ. #2023 and Prep Table EQ. #0138 with 3-Compartment Sink EQ. #2027 and Prep Table EQ. #0171. Re-adjusted the Prep Table and 3-Compartment Sink location so the Prep Table is closer to the door.

- Sheets: A140, A141, A502, A503, P002, P110, P120 & P410
- Attachments: A140




6. **CONDENSER-EVAPORATOR LOW VOLTAGE DROP:** Added keynote #15 on E120 and #7 on E200 indicating low voltage drop for each system to run vertically from evaporators within cooler/freezer to roof top condensers.

- Sheets: E120 & E200
- Attachments: E120




7. **FRYERS CIRCUITS:** Relocated the (4) fryer circuits from MDP. (2) were relocated to Panel B and (2) to Panel A. Relocated the (2) Non-Alch cooler condensers (A-39, 41, 43 & A-40, 42, 44) to MDP.

- Sheets: E110, E430, E431 & E432
- Attachments: E110



8. **MIRROR IN RESTROOMS:** Added power for the mirrors in both Men's and Women's restrooms.

- Sheets: E110 & E430
- Attachments: E110




9. **GAS WATER HEATER:** Removed the circuit from Panel E (E-54) for the gas water heater and replaced with spare.

- Sheet: E431
- Attachments: E431



10. **WATER BOOSTER:** Added water booster #5022 to M-51. Relocated Post Mix system #3005 from M-45 to M-11.

- Sheets: A140, A141, P120, P410, E002, E110 & E431
- Attachments: E110





- Sheet: E430
- Attachments: E430

- Sheet: E430
- Attachments: E430

- Sheet: E431
- Attachments: E431

- Sheet: E430
- Attachments: E430

- Sheet: E431
- Attachments: E431

RaceTrac Store Support Center | 200 Galleria Parkway SE, Suite 900 | Atlanta, GA 30339 | racetrac.com | 770.431.7600

16. **KITCHEN EXHAUST FAN SHUNT:** Added designation “S” under notes to circuit A-37 Kitchen Exhaust Fan Shunt.

- Sheet: E431
- Attachments: E431

S	37	KITCHEN EXHAUST FAN SHUNT	20 A
---	----	---------------------------	------

17. **KSF-1 SHUNT:** Updated the breaker for KSF-1 shunt to be 25amp.

- Sheet: E431
- Attachments: E431

25 A	KSF-1 SHUNT	38
------	-------------	----