

SPB Number: 2024.0104
ELECTRICAL AND LIGHTING UPDATES
 [X] All RW Stores


THE CLIPS BELOW ARE TAKEN FROM THE STANDALONE PROTOTYPE

Issued: 05/10/2024

STANDARD PLAN BULLETIN NOTICE
RaceWay Engineering and Construction Division


- CIGARETTE FIXTURE OUTLETS:** Note added to indicate height and Horizontal indicator for outlets behind cigarette fixture to be 90" AFF.

- Sheets: E111
- Attachment: E111



- E600 CONDUIT UPDATES:** On data closet, conduits to be shown on E111, and coordinate notes from 3/E600 to E111. General Note #4 added.

- Sheets: E111
- Attachment: E111





- UNDERGROUND CONDUIT CLARIFICATION:** Shade in the indicated conduit rough-in indicators to be pulled in through the slab.

- Sheets: E100
- Attachment: E100

CONDUIT	Y---31'-3"
(3) 3/4"	X--6'-9"
CONDUIT	Y---33'-9"
(3) 3/4"	X--6'-9"
CONDUIT	Y---34'-2"
1/2"	X---1'-4"
CONDUIT	Y---36'-0"
1/2"	X---1'-2"


4. **OUTLET UPDATES:** Added note to provide single outlet receptacle for ATM. Added duplex near edge of water fountain.

- Sheets: E110
- Attachment: E110



5. **LINEAR LIGHT UPDATES:** Added key note #4 to call for all suspended linear light fixtures to be mounted at 10'-6" in lieu of 11'-0".

- Sheets: A150
- Attachment: A150



4	LIGHTS TO BE MOUNTED 10'-6" A.F.F.	2.	F
	BRONZE BRACKET METAL PROVIDED AND INSTALLED BY G.C. TO	3.	S